

Phoenix School

3131 NE Diamond Lake Blvd, Roseburg, OR 97470

phone: 541-673-3036 / fax: 541-957-5906 / web: www.roseburgphoenix.com

10/07/16

We're Lead Free!!


Our school's water fixtures, for drinking and food preparation, were tested by Umpqua Research Company for lead on 09/29/19 and NO lead was detected. While no lead was expected, our facility was constructed in 2002, we are reassured that our drinking water and food preparation water sources tested lead free.

Umpqua Research Company is an Oregon Health Authority accredited laboratory for testing lead in drinking water. For more information on how we maintain a safe and health school environment please see our Safe & Healthy School Plan on the bulletin board of our website: www.roseburgphoenix.com. If you'd like to see our lab results please contact our Executive Assistant, Crissy Lindsey, at clindsey@roseburgphoenix.com.

Sincerely,



Ron Breyne
Executive Director



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6092901

Phoenix School of Roseburg 3131 NE Diamond Lake Blvd. Roseburg, OR 97470	Project: Lead and Copper 2016 Project #: Lead and Copper Client Contact: Roger Hill	Date Reported: 10/05/16 Date Received: 09/29/16 09:00 Sampled By: Tom Williams
--	---	--

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6092901-01	Sample Location: Upstairs Drinking Fountain-Lower									
Lead		1030	ND	mg/L	0.002	0.02	09/29/16 07:21	10/03/16	DJP	
Copper			0.088	mg/L	0.010	1.3	09/29/16 07:21	10/03/16	DJP	
6092901-02	Sample Location: Downstairs Drinking Fountain-Upper									
Lead		1030	ND	mg/L	0.002	0.02	09/29/16 07:23	10/03/16	DJP	
Copper			0.091	mg/L	0.010	1.3	09/29/16 07:23	10/03/16	DJP	
6092901-03	Sample Location: Kitchen Sink									
Lead		1030	ND	mg/L	0.002	0.02	09/29/16 07:24	10/03/16	DJP	
Copper			0.042	mg/L	0.010	1.3	09/29/16 07:24	10/03/16	DJP	

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6092901

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.